




# GEV – Classification Criteria

## Requirements for Emission Controlled Installation Products, Adhesives and Building Materials and Award of the EMICODE

(Edition: 22.05.2019 – replaces: 18.04.2018)



## Table of contents

1.	Objective .....	3
2.	Range of application and definitions .....	3
2.1	Installation products .....	3
2.2	Other adhesives .....	3
2.3	Other products.....	3
2.4	Solvents .....	3
2.5	Volatile organic compounds – terms for GEV .....	3
2.5.1	Volatile organic compounds - VOC.....	3
2.5.2	Semi-volatile organic compounds - SVOC.....	3
2.5.3	Very volatile organic compounds – VVOC.....	3
2.6	Emissions.....	3
2.7	Emissions controlled products .....	4
2.8	EMICODE .....	4
3.	Requirements for emissions controlled installation products, adhesives and construction products .....	5
3.1	General requirements.....	5
3.1.1	Chemical laws .....	5
3.1.2	Restrictions of chemicals.....	5
3.1.2.1	Toxic products.....	5
3.1.2.2	CMR substances .....	5
3.1.2.3	SVHC substances .....	5
3.1.2.4	Oximes.....	6
3.1.2.5	Solvents .....	6
3.2	Requirements on emissions .....	6
3.2.1	Volatile carcinogenic substances.....	6
3.2.2	Volatile and semi-volatile organic compounds .....	6
4.	Classification of products.....	7
4.1	Responsibility of the manufacturer.....	7
4.2	Testing .....	7
4.3	Licensing the EMICODE.....	7
4.3.1	Application for a licence.....	7
4.3.2	Awarding of the licence .....	7
4.4	Control checks.....	7
4.5	Authorised testing laboratories .....	7
5.	Accompanying documents .....	8
6.	Changes and adaptations.....	8

## 1. Objective

This document specifies criteria for an evaluation of installation products, adhesives and building materials in conformance with BRCW 3<sup>1</sup> criteria on hygiene, health and the environment and for classification with respect to long-term emissions.

## 2. Range of application and definitions

### 2.1 Installation products

Installation products are materials that are used in buildings for interior finishing mostly as plane products to prepare surfaces and to install or to glue floor, wall or ceiling coverings.

### 2.2 Other adhesives

Other adhesives are products that are used to glue materials and that are not specified under 2.1.

### 2.3 Other products

Other construction products are products referred to in point 2.8 that do not fall into the categories referred to in 2.1 and 2.2.



Classification criteria for products for floor surface treatments (surface coatings/laquers for parquet, as well as lacquers, finishes and oils for mineral floorings, and lacquers for resilient floor coverings) are specified in a separate document.

### 2.4 Solvents

Solvents are volatile organic compounds and their mixtures with a boiling point  $\leq 200$  °C, liquid at normal conditions (20 °C and 1013 hPa), that are used to solve or dilute other substances without changing their chemical characteristics<sup>2</sup>.

### 2.5 Volatile organic compounds – terms for GEV

The definitions of EN 16516 apply to characterise volatile organic compounds that can be emitted into indoor air during normal use.

#### 2.5.1 Volatile organic compounds - VOC

Organic compounds that are detected in the interval of *n*-hexane (*n*-C<sub>6</sub>) to *n*-hexadecane (*n*-C<sub>16</sub>) under the conditions specified in the “GEV Testing Method”.

#### 2.5.2 Semi-volatile organic compounds - SVOC

Organic compounds that are detected after *n*-hexadecane ( $> n$ -C<sub>16</sub>) and before *n*-docosane (*n*-C<sub>22</sub>) under the conditions specified in the “GEV Testing Method”.

#### 2.5.3 Very volatile organic compounds – VVOC

Organic compounds that are detected before *n*-hexane ( $< n$ -C<sub>6</sub>) under the conditions specified in the “GEV Testing Method”.

### 2.6 Emissions

Emissions are all volatile organic compounds that are released from installation products, adhesives and construction products into the surrounding indoor air under normal conditions. The emissions behaviour is monitored in emissions test chambers.

<sup>1</sup> BRCW No. 3 of the Construction Products Regulation (CPR), Annex 1 No. 3b (Basic Requirements on Construction Works).

<sup>2</sup> See TRGS 610.

## 2.7 Emissions controlled products

Emissions controlled products fulfil the requirements as specified in clause 3.1 and 3.2.

## 2.8 EMICODE

EMICODE is a registered mark of the GEV to classify and label emissions controlled products.

The term EMICODE is used to classify products with respect to their emissions always in combination with the applicable emissions class according to 3.2.3 as follows:

EMICODE EC 1 <sup>PLUS</sup> :	„very low emission <sup>PLUS</sup> “
EMICODE EC 1:	„very low emission“
EMICODE EC 2:	„low emission“

The EMICODE can be granted to installation products, adhesives and construction products included in the following groups:

- *Liquid products*  
Precoats, primers, barrier or damp barriers, ready-to-use thin fluid fixations or adhesives, anti-slip coatings for self-laying floor coverings, rolled fixatives, spray adhesives, screw locking adhesives, wood glues, dispersion based additives for mineral tile mortars and levelling compounds, dispersion based bonding courses (e.g. for bonded screeds), cement based waterproofing slurries, liquid sealants, liquid membranes, reactive surface sealants, binders for synthetic resin screed, casting resins
- *Powdery products*  
Cement and calcium sulfate based levelling compounds, cement based and other mineral tile mortars (thin bed and medium bed mortars), mortars for brickwork, cement and calcium sulfate based screed mortars and screed binding materials, powdery and liquid screed admixtures, powdery adhesives (other than tile adhesives), cement based composite waterproofing slurries and coatings, powdery bonding courses (e.g. for bonded screeds), filling and levelling primers, quick cements
- *Pasty products*  
Adhesives for floor coverings, parquet, or ready-to-use adhesives for ceramic tiles, assembly adhesives and other pasty adhesives, pasty fixatives for floor coverings, dispersion based or reactive resin based levelling compounds, sealants under tiles based on dispersions or reactive resins, joint grouts based on dispersions or reactive resins
- *Ready-to-use products that do not require chemical curing or physical drying*  
Underlays (e.g. footfall damping underlays, self-adhesive underlays), adhesive tapes, installation panels, wall panels, decoupling panels, damping panels, planar sealing tapes and collars for small surfaces (e.g. for window, façade, in wet areas), sealing membranes for large surfaces (e.g. for walls and floor in wet areas), vapour retarder under the roof
- *Joint sealants, joint insulations, joint sealing tapes*  
Joint sealants based on dispersions or reactive resins, assembly and insulation foams, compressed sealant tapes according to DIN 18542 and foam sealing tapes

### 3. Requirements for emissions controlled installation products, adhesives and construction products

Installation products, adhesives and construction products shall be safe in use. This includes that they must not, therefore, be hazardous to the health of installers or users and shall have the lowest possible impact on the environment by emissions. For these reasons the following requirements are specified for emissions controlled installation products, adhesives and construction products.

#### 3.1 General requirements

##### 3.1.1 Chemical laws

All legal regulations with regards to production, labelling and packaging must be observed during manufacture of emissions controlled installation products, adhesives and construction products.

A Safety Data Sheet according to local law has to be issued for each emissions controlled product even if this is not legally required.

##### 3.1.2 Restrictions of chemicals

###### 3.1.2.1 Toxic products

Products (mixtures) which are classified according to European Hazardous Substances Regulation (EC) No. 1272/2008 (CLP Regulation) are classified in categories 1, 2 or 3 with regard to their toxic properties (CLP: Part 3: 3.1 acute toxicity) are excluded from the EMI CODE.

###### 3.1.2.2 CMR substances

Products (mixtures) to which substances have been added as constitutional components that are classified as follows with regard to their CMR properties according to European Hazardous Substances Regulation (EC) No. 1272/2008 (CLP Regulation):

- Carcinogen: category 1A or 1B
- Germ cell mutagen: category 1A or 1B
- Toxic to reproduction: category 1A or 1 B

are excluded from the EMI CODE<sup>3</sup>.

Substances with a substance-specific limit value according to point 3.2.1 are unaffected by this.

###### 3.1.2.3 SVHC substances

Products (mixtures) to which the following substances classified as substances of very high concern or suspected substances have been added as constitutional components according to the European Chemicals Legislation are excluded from the EMI CODE:

- Substances that have been included under the Chemicals Regulation REACH (EG 1907/2006) according to Art. 57 in the list (so-called "candidate list") according to REACH Art. 59 Para. 1. At the time of applying for the EMI CODE, the current candidate list applies<sup>3</sup>.
- Substances that are labelled in their safety data sheets with properties that may lead to their inclusion in the candidate list (REACH Art. 57) are treated in the same way as substances already listed on the candidate list<sup>3</sup>.

---

<sup>3</sup> Due to the use of technical raw materials, however, impurities of up to 0.1 % may be detectable in each case.

### 3.1.2.4 Oximes

Products (mixtures) which contain Methyl Ethyl Ketoxime (MEKO, Butanone oxime) or Methyl Isobutyl Ketoxime (MIBKO) or which release them during curing are excluded from EMICODE.

Products (mixtures) containing Acetone oxime or releasing it during curing are excluded from EMICODE as of 01.01.2020.

### 3.1.2.5 Solvents

Emission-controlled flooring installation materials, adhesives and construction products are manufactured without the additive of solvents (see point 2.4).

Solvent-free flooring installation materials, adhesives and construction products may contain a minimum solvent content (< 0.5 % w/w), which may result from contamination of the raw materials being used.

## 3.2 Requirements on emissions

Solvent-free products still may contain and release volatile organic compounds (VVOC, VOC or SVOC), parts of which are released into indoor air during application, but mainly during later occupancy.

To limit these so-called emissions, the following specifications apply to emissions controlled installation products, adhesives and construction products.

### 3.2.1 Volatile carcinogenic substances

A test shall show that emissions of the sum of all volatile carcinogenic organic compounds of category 1A and 1B does not exceed 10 µg/m<sup>3</sup> after 3 days and the emissions of any such individual VOC does not exceed 1 µg/m<sup>3</sup> after 28 days. Testing shall be performed according to the separate document "GEV Testing Method".

Deviating from the above, product emissions after 3 days are limited as follows:

- Formaldehyde (cat. 1B) and acetaldehyde (cat. 2), each must not be above 50 µg/m<sup>3</sup>,
- Sum of formaldehyde and acetaldehyde must not be above 0,05 ppm.

### 3.2.2 Volatile and semi-volatile organic compounds

Determination of volatile organic compounds that might be released from a product during a longer time period is performed as specified in the "GEV Testing Method".

Classification of a product is done on the basis of the results of that test.

Emissions are evaluated after 3 days and after 28 days.

Emissions controlled products must not exceed these maximum emissions levels:

EMICODE	after 3 days TVOC [µg/m <sup>3</sup> ]	after 28 days TVOC / TSVOC [µg/m <sup>3</sup> ]
EC 1 <sup>PLUS</sup>	≤ 750	≤ 60 / ≤ 40
EC 1	≤ 1000	≤ 100 / ≤ 50
EC 2	≤ 3000	≤ 300 / ≤ 100



In addition, products labelled with EMICODE EC 1<sup>PLUS</sup> must comply with the LCI-values and the R-value of the most recent AgBB evaluation scheme after 28 days, and with an upper limit value of 40 µg/m<sup>3</sup> for the sum of non-assessable VOCs (VOCs without LCI-value and non-identified VOCs). Results for acetic acid are not included in the calculation of TVOC and R value because acetic acid cannot be determined with the GEV testing method in a quantitative manner according to EN 16516<sup>4</sup>.

Compliance is given as well if all limit values for a 28 days test are respected at an earlier point in time than after 28 days, but not earlier than after 10 days, provided that there was not observed any increase of emissions compared with the results after 3 days.

## 4. Classification of products

### 4.1 Responsibility of the manufacturer

The manufacturer performs the evaluation whether and which of the before-mentioned specifications are fulfilled by a product in his own responsibility. This concerns especially any changes in recipe that may lead to a re-classification of products.

### 4.2 Testing

Testing to determine product emissions shall be carried out by a laboratory holding an accreditation in accordance with ISO 17025 that includes the “GEV Testing Method” or the EN 16516.

Documentation of the test results is performed according to the manufacturer’s own internal system.

### 4.3 Licensing the EMICODE

#### 4.3.1 Application for a licence

A formal and justified application for a licence to use the EMICODE label can be sent to the GEV if the relevant product meets the specifications of clause 3. A special form is available from the GEV and shall be used for application.

#### 4.3.2 Awarding of the licence

After the licence is granted the product may be labelled with the EMICODE. The word EMICODE shall only be shown in combination with the correct emissions class. Only the GEV document “*Awarding of licence for the use of EMICODE*” may be used for showing compliance of the product with the GEV Specifications and Classification Criteria.

### 4.4 Control checks

The GEV reserves the right to examine the correct classification of any licensed product. GEV follows advice from third parties on incorrect classifications and punishes these according to the sanctions that are specified in the GEV statutes.

For this purpose, GEV uses one or several independent experts who check compliance with the specifications in clause 3. An evaluation of substances as in 3.2.1 and 3.2.2 must be performed only using the analytical procedures described in the “GEV Testing Method” by an authorised laboratory.

### 4.5 Authorised testing laboratories

The Technical Council of the GEV decides on which testing laboratories are accepted for testing in cases of dispute and control for testing. The basic requirement is an accreditation of the chamber testing and of the involved analytical methods according to ISO 17025.

---

<sup>4</sup> According to the experience of the GEV, the LCI-value of acetic acid always is respected clearly.

A participation in round robin tests that allow any interested laboratories to show their performance gives additional indication of qualification to the Technical Council. A current list of authorized laboratories is available at GEV's homepage [www.emicode.com](http://www.emicode.com).

## **5. Accompanying documents**

- GEV Constitution
- GEV Testing Method
- Form Sheets: "Application for Licence" and "Awarding of Licence"

## **6. Changes and adaptations**

The Technical Council of the GEV is responsible for setting specifications and classification criteria. Documentation and adaptation of changes is the responsibility of the GEV.